



वी.एस.पी  
VSP

# RASHTRIYA ISPAT NIGAM LIMITED

## VISAKHAPATNAM STEEL PLANT

### RAW MATERIAL HANDLING PLANT

#### ELECTRICAL SHIFT REPORT

Date: 02/08/2025

Shift: A

Incharge(s): Amit Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-87	BRS acted even though bypassed at I/O rack	BRS cable earth fault found. Field wire removed at I/O rack keeping bypassed	07:00:00	07:30:00	Rectified by general shift and kept in line
2	OHP	TBS on CO-21	LBC not moving	OLR acted. reset done	06:30:00	06:40:00	
3	OHP	CO-11(C/D)	Reported not moving	OLR acted.Reset done	06:15:00	07:00:00	
4	CHP	CC-29(B/D)	Reported not healthy	OLR acted due to over material on belt	11:40:00 11:47:00 11:55:00	11:45:00 11:50:00 12:00:00	
5	CHP	CC-114	Reported not healthy	OLR acted.reset done	10:20:00	10:25:00	
6	CHP	CC-51	Reported not healthy	OLR acted due to over material on belt(4 times acted)	07:40:00 10:50:00 11:20:00 13:10:00	07:45:00 10:55:00 11:25:00 13:20:00	informed to operation
7	CHP	CC-52	Reported not healthy	OLR acted.Reset done	06:20:00 13:50:00	06:25:00 13:55:00	
8	CHP	CC125	Reported not healthy	OLR acted. reset done	09:20:00	09:25:00	
9	CHP	CC34 SCR-2	Reported LT not taking place	PCRD olr acted.Reset done	12:15:00	12:20:00	
10	CHP	CC 34 SCR-2	Reported luffing not taking place	Checked and found working fine	10:20:00	10:30:00	wrong complaint
11	CHP	CC 112 SCR-8	Operator cabin adjustment to be done	Cabin adjustment done	11:15:00	11:30:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 02/08/2025

Incharge(s): Amit Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
12	WT	OT-4	Reported no movement	Drive-1,2 tripped.Rollers found jammed	07:20:00	07:40:00	Informed to operation
13	WT	CO-3(B/D)	Reported not healthy	OLR acted.Reset done	09:20:00	09:30:00	