



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 02/12/2025

Shift: C

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 11A	ZSS CABLE GOT CUT	RECONNECTED PROPERLY	00:35:00	00:50:00	
2	OHP	TBS ON CO 5A	LT TRACK JAMMING	INFORMED TO OPRN	04:50:00	05:00:00	
3	CHP	CC 34 TO CC 37 YARD MACHINES	FEEDER NO 12 TRIPPED IN LBDS 5	ALL MACHINES CABLES CHECKED AND CHARGED ONE BY ONE	23:50:00	00:45:00	
4	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	02:30:00	05:00:00	2 TIMES
5	CHP	SCR 6 ON CC 38 LT	DRIVE TRIPPED DUE TO TRACK JAMMING	RESET AND INFORMED TO OPRN	04:50:00	05:00:00	
6	CHP	SCR 1 ON CC 34 LT	M2 TRIPPING FREQUENTLY	DISCONNECTED	05:10:00	05:35:00	
7	CHP	CC 32	OLR ACTED	RESET	05:10:00	05:20:00	
8	CHP	CC 125	OLR ACTED	RESET	05:50:00	05:55:00	
9	CHP	SCR 3 ON 35 LT	O/T ACTED	RELEASED	05:20:00	05:30:00	
10	WT	CO 3	OLR ACTED	RESET	04:00:00	04:10:00	
11	IOSA	BRC ON OC 15A	ZSS INTERLOCK CAGE STONE STUCK	REMOVED	01:15:00	01:30:00	