



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 25/10/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 25	zss fault,probe damaged	probe replaced	23:30:00	23:46:00	
2	OHP	TBS on CO7A	left b/c not running,fire observed in control cable old joint near CJB of b/c	cable jointed and insulated with PVC tape,	04:15:00	05:00:00	
3	OHP	RSCO10 A(C)	mpcb tripped due to overload	reset	23:00:00	23:10:00	
4	OHP	CO 58(b)	mpcb tripped	made it on	04:00:00	04:15:00	
5	OHP	VF 16 A	mpcb tripped due to loose contact	tightened it	01:30:00	01:45:00	
6	OHP	CO 29	olr acted	reset	22:10:00	22:20:00	
7	OHP	CO 6A	brs not getting reset,,return wire from jod got cut	rejointed	00:30:00	00:50:00	
8	OHP	CO 26	olr acted	reset	04:30:00	04:40:00	
9	OHP	TBS on co 19	Lt not working,M4 mpcb tripped	made it on	05:50:00	06:00:00	
10	CHP	CC 28	olr acted	reset	05:30:00	05:35:00	
11	CHP	CC 31	olr acted	reset	03:10:00	03:20:00	
12	CHP	CC 31 scr 4	b/c not running,fault reset not operated by operator	fault reset done	00:55:00	01:05:00	
13	CHP	CC 107	olr acted	reset	01:10:00	01:15:00	
14	CHP	CC 51	mpd trips 4 times	reset	01:55:00	05:55:00	
15	CHP	C 54	olr acted	reset	01:35:00	05:10:00	6 times
16	CHP	CC 58	tripped due to belt piece stucked in take up pulley	reset	02:45:00	03:00:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 25/10/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
17	WT	OC 1A(B)	tripped due to OLR	reset	04:55:00	05:00:00	