



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 10/08/2025

Incharge(s): Amit Roy,K SANKARA RAO

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-18 TO CO-23 F/G	NOT MOVE OLR ACTED	RESET DONE	23:00:00	23:10:00	
2	OHP	CO-26	REPORTED RED OLR ACTED	RESET DONE	01:30:00 02:55:00	01:40:00 03:10:00	
3	OHP	TBS ON CO-23	LT NOT TAKING PLACE CHECKED DRIVE TRIP	RESET DONE	02:20:00	02:40:00	
4	OHP	CO-87	NOT RUNNING CHECKED OLR ACTED	RESET DONE	03:40:00	03:50:00	
5	OHP	BRC ON CO-31	Reported B/W-1 moving slowly	Checked and electrically found okay.Mechanical side to be checked	02:30:00	04:00:00	Informed to mechanical
6	CHP	CC-54	Reported not healthy	OLR acted.Reset done(2Times)	00:50:00 01:00:00	00:55:00 01:05:00	
7	CHP	CC-51	Reported not healthy	OLR acted.Reset done	05:20:00	05:25:00	
8	CHP	CC-34	Reported not healthy	OLR acted.Reset done	22:20:00	22:30:00	
9	CHP	CC-125	Reported not healthy	OLR acted.Reset done	23:40:00	23:45:00	
10	CHP	CO-44	Reported not healthy	OLR acted.Reset done	02:55:00	03:05:00	
11	WT	OT-2	NOT MOVING CHECK DRIVE-1 TRIP	RESET DONE	02:30:00	02:35:00	