



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 19/09/2025

Incharge(s): V Balaji Naik, Arnab Roy

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	WOBr on CO26	slew not working found drive tripped 2 times	Reset done	15:35:00 21:35:00	15:45:00 21:45:00	
2	OHP	CO87	complaint not healthy found PC operated	Informed to operation to get released	16:30:00	16:55:00	
3	OHP	WOBR on CO26	Inter locking ZSS cage struck	ZSS cage changed with new one	15:30:00	15:45:00	
4	OHP	CO27	OLR acted	Reset done	15:00:00	15:10:00	
5	CHP	CC 26A	TT no power bcz of old joint insulation failure	MCCB tripped , insulation provided	15:15:00	15:30:00	
6	CHP	CC 44	motor MPD trips	reset	17:30:00	17:40:00	
7	CHP	cc 108	motor MPD trips	reset	18:55:00	19:00:00	
8	CHP	CC 39 SCR 3	b/c not running, LT motor 7 mpcb trips	reset	20:00:00	20:10:00	
9	CHP	S1 on Cc40	all drives not working two HT fuses blown out, Drive replaced and connections and parameters entered by ETL	Given for clearance	16:10:00 19:40:00	22:30:00 22:30:00	LT rev not holding given control wires direct from interfacing relay to drive self FWD is ok may check
10	CHP	SCR3 on CC39	* BCnot running signal missing found signal healthy. LT not working M7 MPCB tripped	* found healthy *M7 motor connection removed and then ok	20:00:00	20:10:00	
11	WT	Ot1	drive 1 trips in pgf 1 fault	reset	16:05:00	16:10:00	