



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 28/06/2025

Area: CHP

Equipment	Job
CC-112,111,31,32,33,34,35,40	Conveyor and machines motor TBs covered with belt pieces
CC-39	BRS checking done and bypass removed
CCR and SCR-6	Prosoft modem and antenna installed on both sides and signal strength verified.
SCR-3	New antenna and pigtail changing done
SCR-6	Field switches cleaning done
CC-40,SCR-6	ppm done and boom conveyor motor TB tightness and TB bolt rectification done
RG-building	Cables dressing done
Lighting	CC-53,CC-131 T/E area lighting rectification done