



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 16/01/2026

Incharge(s): Nagendra Midde

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO26	OLR ACTED	RESET	01:00:00 23:45:00	01:10:00 23:55:00	
2	OHP	CO 50	OLR ACTED	RESET	01:35:00	01:45:00	
3	OHP	BRC ON CO 32 B/W NOT RUNNING	GUIDE ROLLER PROBLEM	INFORMED TO OPRN	05:00:00	05:15:00	
4	CHP	SCR 4 ON CC 31 SLEW	RETURN FILTER JAM	FILTER HANDLE DIRECTION CHANGED THEN OK	00:00:00	00:15:00	
5	CHP	CC 125	OLR ACTED	RESET	00:40:00	00:45:00	
6	CHP	SCR 10 ON CC 105 LT	M2 TRIP	RESET	03:00:00	03:15:00	
7	CHP	CC 31	OLR ACTED	RESET	05:35:00	05:45:00	
8	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	00:00:00	03:00:00	4 TIMES
9	CHP	CC 117	OLR ACTED	RESET	03:10:00	03:25:00	
10	CHP	CC 53	T/T F/G OLR ACTED	RESET	23:30:00	23:45:00	
11	CHP	CC 29 T/T NOT MOVING	CABLE LOOSE NEAR PB	TIGHTENED THEN OK	00:00:00	00:10:00	
12	WT	OP 10	DRIVE 6 TRIPPED	RESET	05:50:00	06:00:00	