



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 28/08/2025

Incharge(s): Lal Singh

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-14	ZSS ACTING	WIRE LOOSE IN MODULE ... CONNECTED PROPERLY	10:10:00	10:25:00	
2	OHP	CO-28 BRC	BC DIRECTION CHANGE REQ FOR MATERIAL CLEANING	CHANGED ... AGAIN KEPT IN SAME DIRECTION	07:50:00	08:10:00	
3	OHP	VS-2	TRIPPED ON OL	RESET DONE	09:35:00 12:20:00	09:45:00 12:30:00	
4	OHP	CO-6A WOBR	LT NOT WORKING	BELT ON TRACK ... NO ELECTRICAL PROBLEM	09:00:00	09:20:00	
5	OHP	CO-25 WOBR	BC NOT RUNNING	ZSS INTERLOCK CAGE STUCK ... MADE FREE	09:35:00	10:20:00	
6	CHP	CC-34 SCR-2	LUFF NOT WORKING	FILTER CLOG PROBLEM ...	07:00:00	07:30:00	
7	CHP	CC-112	DE CHUT SENSOR FAILED ...COMPLAINT	IT WAS IN BYPASS SINCE 17 AUGUST AS PER OPERATION REQUEST	09:50:00	10:00:00	kept in ckt
8	CHP	CC-117	TRIPPED MPD ON OL	RESET DONE	08:50:00	09:10:00	