



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 06/01/2026

Shift: B

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	TBS on CO 21	LT not working,PB broken	PB replaced	15:30:00	15:45:00	
2	OHP	BRC 28	pump OL	reset	16:30:00	16:45:00	
3	OHP	TBS on co 24	LT not working,s/s in local	kept in remote	21:21:00	21:31:00	
4	OHP	co 16	olr	reset	18:10:00	18:20:00	
5	OHP	CO 12 A	not running,RSCO1A immediately stop after cmd	rsco 1A 110 v control problem rectified and CO 12 A s/s switch rectified	18:15:00	22:30:00	
6	CHP	CC 34 SCR1	slew not working,jamming	informed operation	15:57:00	16:00:00	
7	CHP	CC 32	olr acted	reset	16:10:00	16:15:00	
8	CHP	CC 34 SCR1	Lt not working,m6,tripped	made on	21:35:00	21:45:00	
9	CHP	CC 51	mpd acted 7 times	reset	15:30:00	21:20:00	
10	CHP	CC 131	olr acted	reset	20:25:00	20:30:00	
11	CHP	CC 114	olr acted	reset	18:39:00	18:49:00	