



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 13/11/2025

Shift: B

Incharge(s): Saurabh Kumar Yadav

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	RSCO6A	olr acted	reset	16:20:00	16:30:00	
2	OHP	VF 1A	olr acted	reset	20:55:00	21:05:00	
3	OHP	co 26	OLr acted	reset	15:45:00	15:55:00	
4	OHP	WOBR on co 26	slew not working,drive tripped	reset	14:45:00	15:00:00	
5	OHP	WOBR on CO 26	LT not working,OT acted	ot released	17:20:00	17:35:00	
6	OHP	BRC on CO 34	emergency PB acted	released	18:00:00	18:20:00	
7	OHP	TBS on CO 21	LT not working,drive tripped	reset	22:00:00	22:10:00	
8	CHP	CC 113 A	motor tripped	reset	15:40:00	15:45:00	
9	CHP	CC 54	OLr acted	reset	15:44:00	17:00:00	3 times
10	CHP	CC 51	MPD tripped 8 times	reset	18:00:00	21:30:00	
11	CHP	CC 34 scr1	LT not working ,ol acted	reset	16:00:00	16:15:00	
12	CHP	CC 38 SCR 6	slew not working,jamming	informed operation	16:10:00	16:20:00	
13	CHP	CC 49	ZSS acted sensor probe problem	probe replaced	16:10:00	16:30:00	
14	CHP	CC 39 SCR 2	slew not working,overload	reset	17:10:00	17:20:00	
15	CHP	CC 31	motor trips due to ol	reset	21:40:00	21:50:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 13/11/2025

Incharge(s): Saurabh Kumar Yadav

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
16	CHP	CC 201	olr acted	reset	19:30:00	19:40:00	
17	WT	OT 3	brake problem,timer,ER contactor stucked	ER contactor and timer replaced	15:00:00	16:00:00	
18	WT	CT 1	inhaul mpcb trips	made it on	21:30:00	21:40:00	
19	WT	OP9	no rev movement,d4 trips in ol	reset	16:00:00	16:10:00	