



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 25/09/2025

Shift: B

Incharge(s): Amit Roy,K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-26	OLR ACTED (2TIMES)	RESET DONE	15:30:00 17:30:00	15:40:00 17:40:00	
2	OHP	CO-29	OLR ACTED (2TIMES)	RESET DONE	17:30:00 19:30:00	17:40:00 19:40:00	
3	OHP	TW-6 CO-18 TO CO-23	OLR ACTED	RESET DONE	15:30:00	15:45:00	
4	OHP	TBS ON CO-22	REPORTED L/LUFF NOT TAKING PLACE CHECKED AND FOUND NO PROBLEM	WRONG COMPLAINT	17:20:00	17:40:00	
5	OHP	WOBR ON CO-25	INTERLOCK ZSS CAGE STUCK UP WITH STONE	STONE REMOVED THAN OK	20:20:00	20:40:00	
6	OHP	CO-15	OLR ACTED (2TIMES) INFORMED TO OPERATION CONVEYOR TO BE CHECKED	RESET DONE	20:40:00	20:50:00	
7	CHP	OT-1	DRIVE -1 TRIP (cgf-1) fault	RESET DONE	18:30:00	18:40:00	
8	CHP	CC-117	OLR ACTED	RESET DONE	17:40:00	18:00:00	
9	CHP	CC-51	OLR ACTED (7TIMES) FEEDING CONVEYOR STOP	RESET DONE	14:40:00	21:20:00	
10	CHP	CC-36 SCR-1	B/W OLR ACTED	RESET DONE	16:40:00	16:55:00	
11	CHP	CC-108	OLR ACTED	RESET DONE	19:45:00	19:50:00	
12	CHP	CC-203,CC- 204, CC-205	OLR ACTED	RESET DONE	20:30:00	20:45:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 25/09/2025

Incharge(s): Amit Roy, K SANKARA RAO

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	CHP	CC-31 SCR-4	LT NOT TAKING PLACE PCRD GUIDE PROBLEM	PCRD GUIDE ADJUSTED AND PCRD CABLE PROPER LAYING WAS DONE	18:00:00	18:30:00	
14	CHP	CC-203	FLAP GATE SIGNAL NOT SHOWING IN CCR	BYPASSED IN PANEL	20:30:00	20:45:00	
15	CHP	CC-25 TT	CHUTE SENSOR ACTING FREQUENTLY	CHECKED AND FOUND MATERIAL TOUCHING WITH SENSOR AND ACTING DURING HEAVY LOAD ON BELT. CHUTE CLEANING DONE AND SENSOR CHECKED AND FOUND OKAY	21:00:00	21:30:00	
16	WT	OT-4	DRIVE -1 TRIP CGF-4 FAULT (2TIMES)	RESET DONE	16:00:00 20:40:00	16:05:00 20:50:00	
17	WT	AF-6	DRIVE TRIP (SPEED DEVIATION FAULT )	RESET DONE	17:30:00	17:50:00	