



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 14/05/2025

Shift: B

Incharge(s): G Eswara Rao

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	tbs on co 7a	It not taking place/m2 olr acted	reset done	15:10:00	15:25:00	
2	OHP	co 16	stopping on healthy stop 2 times	all terminals of c/s chute position and middle jb.then given clearence	17:05:00	17:25:00	
3	OHP	co 14	stopping on healthy stop/	chute posion kept bypass then given clearence	21:00:00	21:15:00	qac 5 DI 110v mcb in off condion at plc panel /made on
4	OHP	co 87	tripped on olr	reset done	15:10:00	15:20:00	
5	CHP	cc 19	tripped on olr	reset done	14:45:00	14:55:00	
6	CHP	scr 3 on cc38	stopping on c/s due jamming	inform to operation	15:00:00	15:15:00	
7	CHP	s1 on cc 35	It not taking place/pcrd cable tension acting due gear box problem	informed to mech.	19:10:00	20:00:00	s1 kept tailend and pcrd power kept off
8	CHP	cc 25	tripped on c/s/due to rain	reset done	17:50:00	18:00:00	mat kept on c/s unit
9	CHP	cc 44	tripped on olr due to more material	reset done	15:35:00	15:45:00	
10	CHP	scr 5 on cc32	bc not running/mpr tripped on ub	motor termination and panel side tightend. then given clearence	14:15:00	15:10:00	
11	CHP	scr 8 on cc112	bw and slewing not taking place	plc power recycle done	20:30:00	21:20:00	



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 14/05/2025

Incharge(s): G Eswara Rao

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
12	WT	cp 2	not running/ communication problem	power recycle done	15:30:00	15:45:00	no delay