



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 22/05/2025

Shift: B

Incharge(s): G Eswara Rao

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	brc 3 on co 28	no drives running/bc ,ct,lt power off condition	poer made on and tested ok	15:45:00	16:00:00	
2	OHP	co 6	pc acted/not getting reset	pc bypassed at cjb for ope. request	15:15:00	15:30:00	
3	OHP	CO 29	PC acted /not getting reset	pc bypassed for operation request	16:00:00	16:10:00	
4	OHP	co-29	tripped on olr	reset done	18:30:00	18:45:00	
5	CHP	cc 131	tripped on olr /due to jamming 4 times	reset done	14:00:00	14:10:00	10.50 to105 5am....01.15 pm
6	CHP	cc-32 scr-5	bc not running	due to over load	16:10:00	16:20:00	
7	CHP	scr-5 cc-32	lt not working	over tension acted ... released	17:00:00	17:10:00	
8	CHP	cc-203	stopping on zss	zss target problem ...bypassed	17:00:00	19:00:00	rarget needs to be fixed
9	WT	OT 1	INITIAL POSITION NOT GETTING	reverse limit adjusted in RL1	14:00:00	14:15:00	
10	WT	cc-3 bd	tripped on olr due to jamming	reset done	17:30:00	17:40:00	
11	IOSA	iosa tbs	communication problem	power recycled	14:00:00	14:15:00	