



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 09/09/2025

Shift: A

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC ON CO-28	YARD CONVEYOR INTERLOCK ZSS CAGE AND PROBE DAMAGED	REPLACED WITH NEW PROBE AND ZSS CAGE THAN OK	07:50:00	08:25:00	
2	OHP	CO-35	OLR ACTED	RESET DONE	10:15:00	10:25:00	
3	OHP	WOBR ON CO-29	LT NOT TAKING PLACE CHECKED M-4 OLR ACTED	RESET DONE	11:10:00	11:30:00	
4	OHP	CO 34	OLR ACTED	RESET DONE	13:00:00	13:10:00	
5	OHP	CO-77	OLR ACTED	RESET DONE	13:10:00	13:20:00	
6	CHP	CC-132	OLR ACTED (2TIMES)	RESET DONE	11:40:00 12:40:00	11:45:00 12:50:00	
7	CHP	CC-54	OLR ACTED (4TIMES)	RESET DONE	10:40:00	12:40:00	
8	CHP	CC-39 S-1	LUFFING NOT WORKING CHECKED AIR LOCK	INFORMED TO MECHANICAL	06:30:00	07:00:00	
9	CHP	CC-36 SCR-1	SLEW NOT WORKING CHECKED AND FOUND SLEW AREA MATERIAL JAMMING	INFORMED TO OPERATION	06:30:00	06:50:00	
10	CHP	CC-34 SCR-2	LT NOT TAKING PLACE DRIVE TRIP	RESET DONE	08:20:00	08:35:00	
11	CHP	CC-36 SCR-1	B/C STOPPING CHECKED MATERIAL OVER LOAD	AFTER CLEAR THE MATERIAL THAN OK	08:40:00	08:50:00	
12	CHP	CC-39	OLR ACTED	RESET DONE	09:00:00	09:10:00	
13	CHP	CC-34	C/S ACTED FREQUENTLY DUE TO WET COAL PILLING IN CHUTE	INFORMED TO OPERATION	10:30:00	11:00:00	