



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 31/12/2025

Shift: B

Incharge(s): Nagendra Midde

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 3B RED	EMERGENCY PB CONTROL FUSE BLOWN	REPLACED	19:00:00	19:25:00	
2	OHP	CO 63	MPCB TRIP	MADE IT ON	21:00:00	21:10:00	
3	OHP	TBS ON CO 5A	LEFT LUFF MPCB TRIP	MADE IT ON	18:00:00	18:10:00	
4	OHP	BRC ON CO 31	CT DRIVE TRIP	RESET	19:30:00	19:40:00	
5	CHP	SCR 5 ON CC 32	B/C OLR ACTED	RESET	18:20:00	18:35:00	
6	CHP	SCR 9 ON CC 104	LUFF MPCB TRIP	RESET	18:30:00	18:40:00	
7	CHP	SCR 3 ON CC 33	B/C OLR ACTED	RESET	21:05:00	21:15:00	
8	CHP	CC 51	FEEDING CONV TRIP	RESET	14:30:00	20:00:00	15 TIMES
9	CHP	CC 131	OLR ACTED	RESET	16:20:00 20:00:00	16:25:00 20:05:00	
10	CHP	CC 52	FEEDING CONV MPD TRIP	RESET	20:00:00	20:05:00	
11	CHP	CC 58	OLR ACTED DUE TO HEAVY LOAD ON CONVEYOR	RESET	21:45:00	22:00:00	INFORMED TO OPRN TO CLEAR LOAD
12	WT	OT2	DRIVE 2 TRIPPED ON PGF1 FAULT	RESET	14:50:00 15:25:00	14:55:00 15:30:00	
13	WT	OT2	DRIVE 1 TRIPPED ON PGF4	RESET	16:45:00	16:50:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 31/12/2025

Incharge(s): Nagendra Midde

Shift: B

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
14	WT	OP4 NOT MOVING	PARKING ZONE TIMER CONTACTOR NEUTRAL MISSING	TIGHTENED THEN OK	20:55:00	21:15:00	