



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 13/02/2026

Area: CHP

Equipment	Job
CC 53	Both Motors Double Earthing provided
CC 53 t/t	Position Sensors and Cable replaced and kept in circuit
CC 25, CC 25 t/t ,CC 26, CC 26 t/t	PPM done
CC 7, 8 , 9	BRS maintenance done
CC 106 TUL	New Chute sensor Fabrication done
SCR 4	Instrumentation sensors maintenance done
CC 106	4*16 Sq mm AL cable laid for Welding Machine supply near Drive end
LC, 18, CM 19, CM 17, CM 18	I/O Rack Prohibus looping cables replaced