



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 20/11/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-16	TRIPPED ON OLR(2TIMES)	RESET DONE	07:40:00 08:20:00	07:50:00 08:30:00	
2	OHP	CO-36	REPORTED BRS NOT RESET	BYPASSED AND CLEARANCE GIVEN	06:45:00	07:00:00	SENSORS ADJUSTED AND KEPT IN CIRCUIT
3	CHP	TT ON CC-26	REPORTED LT NOT WORKING FOUND MPCB TRIP	MADE ON	07:15:00	07:30:00	
4	CHP	CC-54	TRIPPED ON OLR (12 TIMES)	RESET DONE	06:50:00	13:30:00	
5	CHP	CC-51	FEEDING CONVEYOR MPD TRIP	RESET DONE	08:30:00	08:35:00	