



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 30/09/2025

Incharge(s): Amit Roy

Shift: B

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|----------------|---------------------------------------|------------------------------------------------------------------------------|----------------------|----------------------|---------------------------------------------|
| 1 | OHP | TIS-4 ON CO-44 | Reported not healthy | Bypassed as per operation requirement. checked and control problem rectified | 18:00:00 | 20:00:00 | to be kept in line after demand.NO delay |
| 2 | OHP | TBS ON CO-7A | Reported LT not moving | PCRD guide problem.Informed to mechanical | 15:30:00 | 16:00:00 | Guide adjustment done along with mechanical |
| 3 | CHP | CC-32 R-1 | Reported B/C not running | Yard interlock ZSS probe problem. Probe changed and tested okay | 15:00:00 | 15:40:00 | |
| 4 | CHP | CC-40 SCR-3 | Reported LT not taking place | PCRD overtension acted.Released and tested okay | 16:05:00 | 16:25:00 | |
| 5 | CHP | CC-37 SCR-7 | LT not taking place | PCRD overtension acted.Released and tested okay | 19:50:00 | 20:05:00 | |
| 6 | CHP | CC-33 SCR-5 | LT not taking place | Local emergency in acted condition.Released and tested okay | 20:30:00 | 20:40:00 | |
| 7 | CHP | CC-28 | BRS (JOD) bent due to bobcat cleaning | Bent removed and kept in circuit | 16:00:00 | 17:00:00 | No delay |
| 8 | CHP | CC-51 | Reported feeding conveyor tripped | MPD tripped. reset done | 16:10:00 20:35:00 | 16:15:00 20:40:00 | |
| 9 | CHP | RG-1 | Tripped due to rotor jamming | Cleaning done and reset done | 16:55:00 | 21:20:00 | |
| 10 | WT | OP-3 | Reported not moving | Checked and found collector pad damaged.Replaced and tested okay | 18:00:00 | 19:00:00 | No delay as rake wasnt there |



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 30/09/2025

Incharge(s): Amit Roy

Shift: B

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|-----------|----------------------|----------------------------------------------------------------------------------------------------------------------|----------|----------|------------------------------------|
| 11 | WT | OP-10 | Reported not moving | Checked and found breaker tripped in LC-2.Made on and tested okay | 16:30:00 | 16:45:00 | No delay as OT-5 under maintenance |
| 12 | IOSA | OC-18A | Reported not healthy | Control tripping in PLC.Earth fault in field devices found for OC-16A.OC-16A feeder kept off and OC-18A made healthy | 20:45:00 | 21:10:00 | |