



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 25/07/2025

Incharge(s): Arnab Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 9	BRS bypass request	bypassed at module	23:25:00	23:35:00	
2	OHP	CO 33M	OLR acted	reset done	23:23:00	23:35:00	
3	OHP	CO 26	OLR acted	reset done	00:20:00	00:30:00	
4	OHP	VS 1A	OLR acted	reset done	00:05:00	00:10:00	
5	OHP	CO 35	OLR acted	reset done	00:55:00	01:00:00	
6	OHP	TBS on CO 22	Left boom not running	OLR acted, reset done	05:00:00	05:15:00	
7	OHP	WOBR on CO 6A	Yard ZSS cage problem	cage replaced	00:30:00	00:45:00	
8	OHP	CR 2A	Noise coming while running	checked , bearing end cover damaged. Informed to operation	05:00:00	05:30:00	Informed to Gen shift
9	CHP	CC 26 TT	Flap gate MPCB tripped	made on	23:40:00	23:50:00	
10	CHP	CC 34, SCR 2	Slew not working	Drive reset	22:10:00	22:30:00	
11	CHP	CC 44	OLR acted	reset done	23:10:00	23:45:00	
12	CHP	CC 104 , SCR 9	PCRD gearbox problem from B shift	After mechanical work done cable rewinded	23:10:00	23:45:00	
13	CHP	CC 203	OLR acted	reset done	22:30:00	22:50:00	
14	CHP	CC 114	OLR acted	reset done	01:25:00	01:35:00	
15	CHP	CC 54	OLR acted	reset done	03:05:00	03:10:00	
16	CHP	CC 51	stopped on ZSS due to belt overload	informed to operation	00:30:00	00:40:00	