



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 26/12/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-26	OLR ACTED	RESET DONE	06:40:00	06:45:00	
2	OHP	TBS ON CO-20	REPORTED LT NOT TAKING PLACE PCRD O/T ACTED DUE TO GUIDE PROBLEM	INFORMED TO MECHANICAL	10:30:00	10:40:00	
3	OHP	CO-10A	OLR ACTED	RESET DONE	09:35:00	09:40:00	
4	CHP	CC-117	OLR ACTED (5TIMES)	RESET DONE	07:30:00	13:20:00	
5	CHP	CC-51	MPD TRIPPED FEEDING CONVEYOR (14 TIMES)	RESET DONE	08:00:00	13:30:00	
6	CHP	CC-54	TRIPPED ON OLR (8 TIMES)	RESET DONE	08:40:00	13:30:00	
7	CHP	CC-203	REPORTED NOT HEALTHY PULL CHORD ACTED	RELEASED THAN OK	06:40:00	07:20:00	
8	CHP	CC-39 SCR-6	REPORTED B/C NOT RUNNING OLR ACTED	RESET DONE THAN OK	07:30:00	07:40:00	
9	CHP	CC-48	REPORTED BRS ACTED	SENSOR CLEANING DONE THAN OK	10:10:00	10:20:00	