



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 27/01/2026

Area: WT

| Equipment | Job |
|-----------------------|---|
| CP 3 jobs | control cable laying done from main panel to drive panels for out put |
| CP 3 jobs | D 5 and 6 Motor termination done |
| CP 3 jobs | L H S , D B R termination and cable dressing done |
| CP 3 jobs | R H S , D B U and D B R fixing done |
| OP 1 | B-phase O/G terminal bolt replaced in LC 2A panel |
| OP 1 | D6 Motor removed from bed for mechanical/gear box job |
| OP 1,2,3,4,5,6 and 10 | After rake maintenance done |