



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 12/05/2025

Shift: C

Incharge(s): Saurabh Kumar Yadav

| Sl No | Area | Equipment | Problem | Action | From | To | Remarks |
|-------|------|---------------|-----------------------------------------------|----------------------------------------|----------|----------|---------|
| 1 | OHP | BRC on CO 32 | B/C not running,olr acted | reset it | 05:00:00 | 05:10:00 | |
| 2 | OHP | CO 30 A | zss acted,probe damaged | probe replaced | 23:30:00 | 23:45:00 | |
| 3 | OHP | TBS on co 7A | LT not taking place,OT acted | OT released | 05:10:00 | 05:20:00 | |
| 4 | OHP | co 8A | BRS acted,sensor allignment problem | sensor adjusted | 00:30:00 | 00:45:00 | |
| 5 | CHP | CC 34 SCR 2 | B/C not running | check and found all ok,wrong complaint | 01:10:00 | 01:20:00 | |
| 6 | CHP | CC 32 SCR 5 | B/C not running,mpr trps in olr | reset it done | 02:00:00 | 02:10:00 | |
| 7 | CHP | CC 105 SCR 10 | b/c not running,mpd trips due to coal jamming | reset it done and informed operation | 04:30:00 | 04:40:00 | |