



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 10/08/2025

Incharge(s): Lal Singh, Arnab Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 11	Carriage drive mpcb tripped	made on	13:29:00	13:35:00	
2	OHP	CR 1A	Hydraulic pump stopping on fail to start	auxiliary block loose , fixed properly	10:15:00	10:35:00	
3	CHP	CO 87	DMPR tripping in unbalanced current	reset done , contactor and CT terminal checked and tightened	08:20:00	08:45:00	
4	CHP	CC 105 , SCR 7	TUL chute sensor not healthy	checked, coal jamming . Informed to operation	06:45:00	06:55:00	
5	CHP	CC 32 , SCR 5	LT not working	Drive OL tripped , reset done	08:20:00	08:30:00	
6	CHP	CC 34 , SCR 2	BC frequently stopping	ZSS cage got stuck , cage replaced	09:40:00	10:00:00	
7	CHP	CC 112 , SCR 8	Luff down limit bypassed in IO rack	operation request	11:50:00	12:00:00	
8	CHP	CC 34 , SCR 2	LT not working	PCRD overtension acted, released	12:00:00	12:10:00	
9	CHP	CC 125	OLR acted	reset done	12:10:00	12:15:00	