



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 10/12/2025

Shift: A

Incharge(s): K SANKARA RAO

| Sl No | Area | Equipment    | Problem  | Action   | From     | To       | Remarks |
|-------|------|--------------|--|--|----------|----------|---------|
| 1     | OHP  | BRC ON CO-28 | REPORTED B/W-2 NOT RUNNING CHECKED AND FOUND MULTI DISK DAMAGED                | INFORMED TO MECHANICAL                             | 06:50:00 | 07:10:00 |         |
| 2     | OHP  | TBS ON CO-22 | REPORTED LBC STOPPING ON ZSS FOUND ZSS CAGE STUCK UP WITH STONE                | REMOVED THAN OK                                    | 07:50:00 | 08:05:00 |         |
| 3     | OHP  | CO-26        | TRIPPED ON OLR   | RESET DONE   | 13:10:00 | 13:20:00 |         |
| 4     | OHP  | CO-111 B/D   | TRIPPED ON OLR   | RESET DONE   | 11:00:00 | 11:05:00 |         |
| 5     | OHP  | RSCO-10A     | STOPPING ON ZSS FOUND ZS PROBE FIXING CHECK NUT LOOSE                          | ZSS PROBE GAP ADJUSTED AND CHECK NUT TIGHT THAN OK | 12:40:00 | 12:55:00 |         |
| 6     | OHP  | CC-51        | MPD TRIPPED FEEDING CONVEYOR STOP (16 TIMES)                                   | RESET DONE   | 07:10:00 | 13:35:00 |         |
| 7     | CHP  | CC-53        | MPCB TRIPPED   | MPCB MADE ON THAN OK                               | 13:15:00 | 13:30:00 |         |
| 8     | CHP  | CC-51        | TRIPPED ON OLR (2TIMES)  | RESET DONE   | 09:10:00 | 09:20:00 |         |
| 9     | CHP  | CC-130       | REPORTED NOT RUNNING CHECKED AND FOUND VFD DRIVE CONTROL WIRE LOOSE CONNECTION | RECTIFIED THAN OK                                  | 12:15:00 | 13:15:00 |         |
| 10    | CHP  | CC-104 SCR-9 | REPORTED SLEW NOT WORKING LIMIT ACTED DUE TO JAMMING INFORMED TO OPERATION     | AFTER CLEAR THE MATERIAL LIMIT RELEASED THAN OK    | 07:30:00 | 07:50:00 |         |
| 11    | CHP  | CC-125       | TRIPPED ON OLR   | RESET DONE   | 08:50:00 | 08:55:00 |         |
| 12    | IOSA | BRC          | CT END LIMIT ACTED   | RELEASED   | 07:00:00 | 07:10:00 |         |