



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 20/01/2026

Area: CHP

Equipment	Job
All yard machines	Lighting inspection was done
CC 112,111,31,32,33	HT coupler space heaters inspected and rectified ckt problems
CC 52	Defective drive removed and shifted to CM 18
CC 213	Lighting power restored
CC 41/43 tunnel	6 nos 30W LED lamps replaced
CC 107	Running inspection and vibration readings noted
LC 6	I/C-1 charged and found after sometime HT tripped. Informed DNW