



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 22/01/2026

Incharge(s): Amit Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	BRC on CO-28	Reported B/W's not rotating	Oil level low	08:45:00	09:00:00	Informed to mechanical
2	OHP	CO-33M	Reported tripped	OLR acted.Reset done	10:30:00	10:35:00	
3	OHP	BRC on CO-33M	LT not taking place	PCRD tension acted.Released and tested okay	11:30:00	11:40:00	
4	OHP	BRC on CO-33M	Reported B/C stopping frequently	Chute sensor touching with chute plate.Bypassed due to operation requirement	12:30:00	12:45:00	To checked and put in line
5	OHP	CO-13(B/D)	Reported tripped	OLR acted.Reset done	10:55:00	11:00:00	
6	CHP	CC-108	Reported tripped	OLR acted.Reset done(2 times)	08:15:00	08:50:00	
7	CHP	Cc-213	Reported C/S acted	Acted due to coal and moisture mixture accumulation.Probe cleaned and tested okay	09:30:00	09:40:00	