



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 06/06/2025

Area: OHP

Equipment	Job
DE-5	Fan-2 DMPR replacement and testing done
OM-9,10,LC-6	I/O rack maintenance done
CO-42A	Hoist PPM done
CO-11A,12A,13A,14A,42A,49	Belt scale maintenance done
TT-1,2	Panel maintenance done
CO-3A,TT4	Motor and panel PPM done
RSCO-10A	Burnt motor sent to ERS.ZSS bigger probe fixed and tested okay
CO-14,15,16	Chute sensor maintenance done
CO-8,9,10,2A	Chute sensor maintenance done.CJB and PJB blowing done
BRC ON CO-32	B/C CJD canopy provided
TBS ON CO-22,24	Inspection done
BRC-5 ON CO-34	LT brake checking done and found coil burnt.Brake removed.To be replaced
TBS-1 ON CO-21	PPM done
BRC-2 ON CO-28	PPM done
TBS-4 ON O-5A	PPM done