



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 11/02/2026

Area: OHP

| Equipment | Job |
|---|---|
| co-33m,33s brc-3 on co-33m | motor and panel side ppm is done |
| co-26 spare | coupling is removed and sent for overhauling. another spare is found, trail run taken, coupling fixed and shifted to co-26 head end area. |
| wobr-1 on co-29 | bucket wheel motor replaced ; failed motor coupling is removed and sent to ers. sapre 37kw motor shifted from lc7 to hvmcc-1, coupling is fixed and kept ready. |
| om 10 to om-24 control supply | cable for io rack control supply is traced, checked and charged. to be connected at om24 io rack. |
| co-3b; co-66,69 | motor and panel side ppm is done. |
| co-8 pullchord | checked and kept in circuit. |
| co-3a | spare core from brs point to io rack is identified for mechanical brs and is brought to io,, to be programmed in circuit. |
| co-12a h/e hoist | ppm is done |
| co-10a,rco-6a,rsco-1a, vf-1a,2a, bf-3a,4a,5a ; rsco-2a,rbf-1a,2a,3a | motor side ppm is done |
| co-11a gallery | lighting and sockets supply separation is under process. |
| rsco-1a spare motor | received from ers at lc7 |