



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 03/07/2025

Area: CHP

Equipment	Job
CC 56 spare motor	Made ready and shifted to JH C 9
CC 41/42 tunnel	4 nos lamp fixtures replaced and ckt problems rectified
Polymer sheets	Drilling done on the plates and made ready for CJD modification
CC 104,105,33,34,44,41,47,50,108,125,SCR 2,4,9,10	Running inspection was done
CC 36,38,39,40,104,105,SCR 3,6,7,9,10,S 1	Belt covers provided on all the motors
CC 35,SCR 1	PPM was done