



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 26/09/2025

Area: WT

Equipment	Job
EOT Crane(O)	panel and motor side ppm done,B phase termination found loose @pad,tightened .
EOT Crane(O)	Cabin walls welding done