



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 17/01/2026

Area: CHP

Equipment	Job
JH 17 Sump pump	Replaced the motor,AL cable replaced with CU cable,termination done and de watering done
CC 52,VF	Hoist panels maintenance was done
CC 34,111,130,S3,SCR 1	PPM was done
COAL COMPLEX	Rooms cleaning done