



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 19/02/2026

Incharge(s): Nagendra Midde

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO 85	OLR ACTED	RESET	08:30:00	08:35:00	
2	OHP	CO 34	OLR ACTED	RESET	09:00:00	09:20:00	
3	OHP	TBS ON CO 7A	MAIN CONTROL MCB TRIP	MADE IT ON	12:40:00	13:10:00	
4	CHP	CC 201	OLR ACTED	RESET	07:25:00	07:30:00	
5	CHP	CC 203	OLR ACTED	RESET	07:25:00	07:30:00	
6	CHP	SCR 1 ON CC 34 SLEW	CONTROL MCB TRIP	MADE IT ON	10:30:00	10:40:00	
7	CHP	CC 117	OLR ACTED	RESET	09:15:00	09:25:00	
8	CHP	CC 58	OLR ACTED	RESET	12:15:00	12:30:00	
9	CHP	CC 51	FEEDING CONV OLR ACTED	RESET	12:30:00	12:35:00	