



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 29/05/2025

Area: CHP

| Equipment   | Job   |
|---|---|
| CC 33   | Module out going power finger contacts replaced |
| CC 31   | Motor TB cover fixed                            |
| SCR 5   | PCRD guide adjusted and cable winding done      |
| CC 37,111,112,SCR<br>8,S3,201,202,203,204,205,206 | PPM was done                                    |
| SCR4,SCR 8  | Running inspection was done                     |