



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 20/12/2025

Incharge(s): Saurabh Kumar Yadav

Shift: B

| Sl No | Area | Equipment    | Problem   | Action    | From     | To       | Remarks |
|-------|------|--------------|---|-----------|----------|----------|---------|
| 1     | OHP  | CO 111(b)    | olr acted   | reset     | 15:30:00 | 15:35:00 |         |
| 2     | OHP  | co 46        | pc acted  | reset     | 14:50:00 | 14:55:00 |         |
| 3     | OHP  | TBS on CO 20 | Left B/C olr acted  | reset     | 18:30:00 | 18:45:00 |         |
| 4     | OHP  | VS 2A        | OLR acted   | reset     | 20:32:00 | 20:40:00 |         |
| 5     | OHP  | CO 25        | OLR acted   | reset     | 20:40:00 | 20:50:00 |         |
| 6     | CHP  | CC 25 TT     | position indication missing,loosed connection in i/o rack | tightened | 16:20:00 | 16:30:00 |         |
| 7     | CHP  | cc 45        | olr acted   | reset     | 16:30:00 | 16:40:00 | 2 times |
| 8     | CHP  | CC 51        | mpd tripped   | reset     | 17:54:00 | 18:00:00 |         |
| 9     | CHP  | CC 54        | OLR acted   | reset     | 20:10:00 | 20:15:00 |         |
| 10    | CHP  | cc 58        | OLR acted   | reset     | 18:42:00 | 18:51:00 | 2 times |
| 11    | WT   | OT 4         | D1 tripped in pgf1 fault                                  | reset     | 16:00:00 | 16:10:00 |         |