



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 17/12/2025

Area: WT

Equipment	Job
OP 1	D4 motor changing alignment and testing done, removed motor shifted
OP 3,4 and 6	After rake maintenance done
CO 2 level	Area lighting cable found cut ,10 mtrs cable laid and connected.