



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 09/01/2026

Area: OHP

Equipment	Job
brc-4 on co-28	oil level switch and suction line switch, checked and restored in circuit. nitrogen is filled and restored acc2 also in circuit.