



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 24/10/2025

Area: CHP

Equipment	Job
CC 201,222,223	Belt scale maintenance was done
Repair shop	Motor relay and cable replaced,ckt problems rectified
SCR 2	LT end limit striker welded and tested
SCR 1	Both MCCs, operator cabin blowing and cleaning done.ALL MOTORS EXTERNAL CLEANING DONE.
CC 7,9,12,20,21,34,104,108,219,223,SCR 2,SCR 9	PPM was done