



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 30/07/2025

Shift: A

Incharge(s): K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-7	REPORTED HEALTHY STOPPING	CONTROL WIRES TIGHT IN CJB THAN OK	07:45:00	08:00:00	
2	OHP	CO- 35	OLR ACTED	RESET	09:00:00	09:10:00	
3	OHP	WOBR ON CO-26	SLEW NOT TAKING PLACE DRIVE TRIP	RESET	10:30:00	10:45:00	
4	OHP	CO-7	STOPPING ON HEALTHY	PULL CHORD FIELD WIRES REMOVE AND BYPASS IN CJB THAN OK	10:00:00	10:15:00	
5	OHP	CO 10A	OLR ACTED	RESET	12:10:00	12:20:00	
6	CHP	CC 23	STOPPING ON ZS PROBE DAMAGED	ZS PROBE REPLACED THAN OK	11:40:00	12:00:00	
7	CHP	CC-117	OLR ACTED(4TIMES)	RESET	07:30:00	12:20:00	
8	CHP	CC-51	OLR ACTED	RESET	09:30:00	09:40:00	
9	CHP	CC-54	OLR ACTED(4TIMES)	RESET	07:30:00	12:10:00	
10	CHP	CC 105 SCR7	B/C STOPPING FREQUENTLY DUE TO SIGNAL MISSING	LT MOVE FWD DIRECTION THAN OK	09:30:00	09:40:00	
11	CHP	CC-203	OLR ACTED	RESET	09:44:00	09:50:00	
12	CHP	CC-36 S-2	LT NOT TAKING PLACE PCRD GUIDE PROBLEM	PCRD CABLE LAYERING ADJUSTED THAN OK	10:45:00	11:00:00	
13	CHP	CC-32 SCR5	LT NOT TAKING PLACE O/T ACTED	RELEASED	11:40:00	11:55:00	
14	CHP	ALL STACKING STEAM RED	LC-15 PLC ACTIVE BLINKING	POWER RECYCLED THAN OK	07:30:00	08:00:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 30/07/2025

Incharge(s): K SANKARA RAO

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
15	CHP	RG-1 RG-2	STOPPING CHECKED NO PROBLEM FOUND	CLERANCE GIVEN	12:45:00	13:05:00	
16	WT	CO-2 BELT DRIVE	REPORTED RED CHECKED POWER MCB TRIP	POWER MCB MADE ON	07:00:00	07:10:00	DUE TO MATERIAL JAMMING
17	WT	AIR COMPRESSOR	AIR COMPRESSOR NOT WORKING E/STOP ACTED	E/STOP RELEASED THAN OK	07:20:00	07:30:00	
18	WT	OT-4	DRIVE 1 TRIP	RESET	08:40:00	08:50:00	
19	WT	OC-1A	OLR ACTED	OLR RESET	08:50:00	09:00:00	
20	WT	CO-3 BELT DRIVE	OLR ACTED	RESET	11:00:00	11:10:00	
21	WT	CP-3	NOT MOVING I/C-2 LC10A TRIP DUE TO BETWEEN COL NO 44-45 PUSHER BOTTEM COLLECTOR DAMAGE	I/C -2 CHARGED THAN OK	12:45:00	13:00:00	