



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 16/10/2025

Area: WT

Equipment	Job
LC 9	Submersible pump near steps shifted and kept in pit and connected ,burnt pump sent ERS
OP 4	Trolley line inspection done,found Aluminium Bus bar lifted up @ col no 46, rectified it
OP 3	Motor side ppm done, found one bed bolt and sims missing in D1 motor ,provided
OP 1,4 and 5	After rake, maintenance done