



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED

VISAKHAPATNAM STEEL PLANT

RAW MATERIAL HANDLING PLANT

ELECTRICAL SHIFT REPORT

Date: 21/08/2025

Shift: A

Incharge(s): Amit Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-29	Reported tripped	OLR acted.reset done	10:15:00	10:20:00	
2	OHP	CO-12(C/D)	Reported tripped	OLR acted.Reset done	10:20:00	10:25:00	
3	OHP	RSCO-10A(C/D)	Reported not moving	Tripped on olr.Reset done	12:10:00 12:25:00	12:15:00 12:30:00	
4	OHP	WOBR on CO-26	Reported slew not taking place	Drive tripped on OLR.Reset done	13:40:00	13:50:00	
5	CHP	CC-51	Reported tripped	OLR acted(5times)	11:00:00	12:00:00	
6	CHP	CC-34 SCR-2	Reported LT not taking place	PCRD OT acted.Released and tested okay	08:18:00	08:30:00	
7	CHP	CC-45	Reported ZSS problem.	bypassed due to demand.	10:38:00	10:50:00	Probe to be changed
8	CHP	CC-48	Reported D/E CJD not working	Cable damaged. Rejoint done and tested okay	11:15:00	11:25:00	
9	CHP	CC-201	Reported tripped	OLR acted.Reset done	11:23:00	11:30:00	
10	CHP	CC-104 SCR-9	B/W not rotating	Operator cabin reset done and tested okay	12:30:00	12:50:00	
11	WT	OP-10	Reported not moving	C clamp fallen down at column no.64.C clamp kept in position and tested okay.Breaker tripped. made on	10:30:00	10:50:00	C clamp to be changed
12	WT	OP-1	Reported not moving	Drive-4 tripped.Motor lug got cut and base bolts and brushes also damaged.Relugging done,base bolts(2nos.)changed and brushes changed by general shift	11:40:00	13:50:00	



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 21/08/2025

Incharge(s): Amit Roy

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	WT	OT-3,4 hopper lighting	Reported no lighting	Fuse and base burnt. Replaced with new set and lighting restored	11:00:00	11:30:00	