



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 12/07/2025

Area: CHP

Equipment	Job
Misc	cc-53 spare motor shifted to 53 level
Lighting	SCR-10 cabin to yard focussing light fixed, CM-19 and JH-19 road focus lighting done
SCR-8	CCR communication healthy bit programmed and tested
Lighting	CC-34 and 35 T/E lighting defects rectified
CC-34,SCR-2	ppm done
CC-34,SCR-2	TUL chute sensor and discharge chute sensor modification done with polymer sheets