



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 01/08/2025

Area: IOSA

Equipment	Job
1-142LC-3	DNW HAS COME TO CHECK INCOMER-1, AS IT HAS TRIPPED YESTERDAY ON E-FAULT. FOUND FLASH IN CUBICLE. PRESENTLY LOAD IS ON INCOMER-2 AND BUSCOUPLER IN PCC.
WOBR-FLS	DAMAGED and UN-USED LUBRICATION PANEL REMOVED FROM BOOM CONVEYOR AREA.
OC-6A	PPM DONE ON MOTOR AND FIELD DEVICES.