



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL GENERAL SHIFT REPORT

Date: 05/01/2026

Area: WT

Equipment	Job
OP 7	Trolley line inspection done and noted defects
OP 5	Panel and Motor side ppm done
OP 5	Anti collision sensor circuit checked found sensor not functioning
OP1,3,4 and 5	After rake maintenance done
OP 4	D1 and 2 cascade panel " AR" relay replaced
OC1A level	120w LEDs installed 2 nos, near crane approach point