



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 16/06/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav, K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CR 1	SHOWING OIL LOW LEVEL	SENSOR ADJUSTED	06:30:00	06:40:00	
2	OHP	CO 43A	NO POWER CONTROL MCB TRIP DUE TO PULL CHORD EARTH FAULT	FIELD WIRES REMOVED AND PC BYPASS THAN OK	07:30:00	08:00:00	
3	OHP	WOBR ON CO29	CABAN ADJUSTMENT DRIVE NOT WORKING CABLE GOT CUT	JOINT DONE THAN OK	07:00:00	07:30:00	
4	OHP	BRC ON CO 8A	B/C OLR ACTED	reset it done	07:45:00	11:00:00	belt fully loaded with material//// 3 times
5	OHP	BRC on 32	CT not working, limit acted operator cabin side	limit released	12:00:00	12:40:00	
6	OHP	CO 35	olr acted	reset it done	12:30:00	12:40:00	
7	CHP	CC 40 scr 6	b/c not running, c/s acted, full jamming	informed operation	07:20:00	07:30:00	
8	CHP	CC 39	OLR acted	reset it done	07:45:00	07:50:00	
9	CHP	CC 39 SCR 7	slew not working, break fail alarm in spider	reset it done	08:30:00	08:40:00	
10	CHP	CC 32 SCR 5	slew complaint, wrong complaint, LT not working, mpcb 2 trips	made it on	09:30:00	09:40:00	
11	CHP	CC 44	olr acted	reset it done	11:20:00	11:25:00	5 times, belt full load condition informed operation



वी.एस.पी
VSP

RASTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 16/06/2025

Shift: A

Incharge(s): Saurabh Kumar Yadav, K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
12	CHP	CC 36 SCR1	BC position not showing	position bit bypass in i/o rack	11:00:00	11:15:00	magnetic switch to be replaced
13	CHP	CC 54	olr acted	reset it done	07:30:00	07:40:00	
14	IOSA	oc 7a 2a 3a	showing red	lbds 2 plc power re cycled than ok	09:00:00	09:20:00	