



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL GENERAL SHIFT REPORT**

Date: 11/06/2025

Area: CHP

Equipment	Job
CC 34, 105,50,S!,SCR 10	Running inspection was done
SCR 10	MODEM and Antenna fixed ,communication established with CCR and trail run was taken
CC 21	Carriage drive Brake adjusted
CCR	8 nos tube fixtures replaced and ckt problems rectified
CC 25/26 gallery	3 nos 200W led fixtures replaced
CC 13	Motor realigned
CC 13	New control cable connected at panel and control JB and tested all inputs
R 3	Conveyor piece provided to protect interlock cage from coal falling
CC 31	New control JB provided and control wiring done