



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 17/05/2025

Incharge(s): Lal Singh

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-35	TRIPPED ON OVER LOAD	RESET DONE	11:15:00 12:20:00	11:20:00 12:25:00	
2	OHP	CO-27A	PENDING FROM C SHIFT	LOOSE CONNECTION FOUND AT MCCB ON CONTROL TB ... TIGHTENING DONE AND TESTED	06:00:00	06:40:00	
3	OHP	CO-32 BRC	LT NOT WORKING	PCRD TENSION ACTING DUE TO BUSHES ... INFORMED OPERATION FOR CUTTING	08:40:00 10:00:00	09:00:00 10:20:00	
4	OHP	CO-21 TBS	LT NOT WORKING	PCRD CHAIN SPROCKET PROBLEM ... INFORMED MECHANICAL AND OPERATION	09:00:00	09:30:00	
5	CHP	CC-103	STOPPED ON ZSS	COAL STUCK IN ZSS CAGE ... REMOVED AND TESTED	11:00:00	11:10:00	
6	CHP	CC-111	BRS NOT GETTING RESET	BYPASSED IN SYSTEM	07:30:00	07:40:00	
7	CHP	CC-36 SCR-1	BC NOT STARTING	BELT SWAY ACTED ... RELEASED	08:30:00	08:50:00	
8	CHP	CC-36 SCR-1	BW NOT WORKING	OVER LOD ACTED RESET DONE	11:00:00	11:10:00	
9	CHP	CC-104 SCR -9	BOOM POSITION SWITCH PROBLEM	BYPASSED IN IO RACK	10:20:00 13:30:00	10:30:00 13:40:00	
10	CHP	CC-131	TRIPPED ON OVER LOAD	RESET DONE	09:45:00	09:50:00	
11	WT	OT-2	DRIVE 1 TRIPPED ON PGF FAULT	RESET DONE	13:49:00	13:55:00	