



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 25/05/2025

Shift: A

Incharge(s): V Balaji Naik,G Eswara Rao

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	co 26	tripped on olr	reset done	10:45:00	11:00:00	
2	OHP	brc on co 30	bw 1 not running/olr acted	reset done	11:00:00	11:15:00	
3	OHP	brc on co 33m	hydrolic pump not running/oil level low	inform to ope. and mech	12:45:00	13:00:00	/
4	OHP	CO29	over load trip	Reset done	14:00:00	14:00:00	02.35pm to 02.40pm
5	OHP	WOBR on CO26	LT not working found PCRD over tension limit acted	Released then ok	14:00:00	14:00:00	05.30pm to 05.50pm
6	CHP	CC131	Over load trip Scraper deflector plate jam( more than 5 times)	Reset done	09:16:00	09:20:00	Scraper plate removal is planned after shut down by mechanical
7	CHP	CC115	Running imspection defect rectified	One phase incoming cable carbon formed, cable damaged(R phase) MCCB module replaced with 250A	08:15:00	08:35:00	
8	CHP	cc 125	tripped on olr	reset done	12:50:00	13:00:00	
9	CHP	CC114	Tripped due to over load	Reset done	06:50:00	07:00:00	
10	CHP	SCR1 on CC36	Yard motor ZSS kept in ckt, luffing area jamm cleared	Luffing limit kept in ckt	06:30:00	06:40:00	
11	CHP	SCR4 on CC33	LT not working found PCRD cable over tension acted	Tension released then ok	07:00:00	12:07:00	



वी.एस.पी  
VSP

**RASTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 25/05/2025

Incharge(s): V Balaji Naik, G Eswara Rao

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
12	CHP	S1 on CC34	LT not working found PCRD over tension acted	Tension released then ok	07:20:00	07:30:00	
13	CHP	CC41	Motor stopping frequently found CJB cable damaged	Spare cable replaced then ok	09:00:00	09:20:00	
14	CHP	CC125	Motor over load MPD trip	Reset done	12:50:00	12:55:00	
15	CHP	CC44	Motor not running MPD trip in over load due to over feeding	Reset done	13:00:00	13:10:00	
16	CHP	CC125	over trip	Reset done	14:00:00	14:00:00	04.47pm to 04.55pm
17	WT	OP9	Not moving found reached to no power zone at parking area	By providing jumpers bring back to power zone	09:30:00	09:45:00	Not a delay no rake