



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 16/12/2025

Shift: C

Incharge(s): Amit Roy

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CBMS-1A on CO-11A	Reported not healthy	Checked and found not healthy. Belt MPCB auxiliary contact not making. Contact bypassed	03:35:00	04:00:00	MPCB auxiliary contact to be changed
2	OHP	CO-25	Reported tripped	OLR acted. Reset done(2 times)	23:40:00	03:05:00	
3	OHP	CO-26	Reported tripped	OLR acted. Reset done(2 times)	00:00:00	01:40:00	
4	OHP	WOBR on CO-25	Reported yard interlock missing	Cage stuck. Made free and tested okay	00:40:00	00:50:00	
5	OHP	WOBR on CO-25	Slewing not taking place	Drive tripped. Reset done	02:50:00	03:00:00	
6	OHP	BRC on CO-32	LT not taking place	OT acted. Released and tested okay	02:50:00	03:00:00	
7	OHP	Co-111	Reported tripped	OLR acted. Reset done	04:45:00	04:55:00	
8	OHP	CO-29	Reported tripped	OLR acted. Reset done	05:00:00	05:05:00	
9	OHP	BRC on CO-28	CT striker damaged. Pending from B shift.	Striker welded and tested okay	02:25:00	02:45:00	
10	OHP	BRC on CO-28	ZSS interlock problem	Cage replaced and tested okay	03:10:00	03:30:00	
11	CHP	CC 34 SCR-1	LT not working	Drive tripped. Reset done	22:50:00	23:05:00	
12	CHP	CC 34 SCR-1	Slew not working	Drive tripped. Reset done	04:20:00	04:40:00	



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 16/12/2025

Incharge(s): Amit Roy

Shift: C

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
13	CHP	Cc 109 SCR-9	Luffing not working	MPCB tripped.Reset done	23:35:00	23:50:00	
14	CHP	CC 31	Reported tripped	OLR acted.Reset done	02:15:00	02:25:00	
15	CHP	CC- 54	Reported tripped	OLR acted.Reset done(8 times)	02:15:00	05:27:00	
16	CHP	CM 15,16	Communication problem	OLM changed with patchchords but still persisting. Profibus cable planned to be laid between two CM's	22:00:00	06:00:00	