



वी.एस.पी  
VSP

**RASHTRIYA ISPAT NIGAM LIMITED**  
**VISAKHAPATNAM STEEL PLANT**  
**RAW MATERIAL HANDLING PLANT**  
**ELECTRICAL SHIFT REPORT**

Date: 08/08/2025

Shift: C

Incharge(s): Amit Roy,K SANKARA RAO

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	RSCO-2A(B/D)	REPORTED STOPPING ON ZSS CHECKED PROBE DAMAGED	ZSS PROBE REPLACED THAN OK	01:45:00	02:30:00	
2	OHP	CO-10A	REPORTED RED OLR ACTED	OLR RESET DONE	03:30:00	03:40:00	
3	OHP	RSCO-10A (C/D)	NOT MOVED CHECKED OLR ACTED	RESET DONE	04:05:00	04:15:00	
4	OHP	CO-26	REPORTED RED OLR ACTED	RESET DONE	04:30:00	04:40:00	
5	OHP	WOBR ON CO-29	B/C STOPPING ON ZSS CHECKED ZSS PROBE WIRE GOT CUT	ZSS PROBE WIRE JOINT DONE THAN OK	04:40:00	05:00:00	
6	OHP	CO-35	REPORTED RED OLR ACTED	RESET DONE	05:00:00	05:10:00	
7	OHP	RSCO-1A(C/D)	NOT TAKING PLACE OLR ACTED	RESET DONE	23:55:00	00:05:00	
8	OHP	CO-11(C/D)	NOT TAKING PLACE CHECKED OLR ACTED	RESET DONE	23:45:00	00:00:00	
9	OHP	CO-29	REPORTED RED OLR ACTED	RESET DONE	23:05:00	23:15:00	
10	CHP	CC-29 F/G	REPORTED NOT MOVING OLR ACTED	RESET DONE	22:55:00	23:05:00	
11	CHP	CC-54	REPORTED RED OLR ACTED (3TIMES)	RESET DONE	23:30:00	00:15:00	
12	CHP	CC-114	STOPPING ON ZSS DUE TO BELT SNAP	INFORM MECHANICAL	04:10:00	04:30:00	
13	CHP	CC-116	STOPPING ON ZSS CHECKED MECHANICAL PROBLEM	INFORM MECHANICAL	01:30:00	01:50:00	
14	CHP	CC125	Reported not healthy	OLR acted. reset done	02:05:00	02:15:00	