



वी.एस.पी
VSP

RASHTRIYA ISPAT NIGAM LIMITED
VISAKHAPATNAM STEEL PLANT
RAW MATERIAL HANDLING PLANT
ELECTRICAL SHIFT REPORT

Date: 07/12/2025

Incharge(s): Lal Singh,Lal Singh

Shift: A

Sl No	Area	Equipment	Problem	Action	From	To	Remarks
1	OHP	CO-25	TRIPPED ON OLR	RESET DONE	07:30:00	07:40:00	
2	OHP	CO-8A BRC	BW-2 STOPPING ON ZSS	STONE STUCK IN BUCKET ...	11:00:00	11:20:00	
3	OHP	BRC-8A	BW-2 NOT WORKING	RELAY COIL WIRE LOOSE ... CONNECTED PROPERLY	11:30:00	12:00:00	
4	CHP	CC-112 SCR-8	LT NOT WORKING	PCRD PROBLEM 12KA5 COIL WIRE REMOVED	06:30:00	06:40:00	
5	CHP	SCR-10 CC-105	LT NOT WORKING ... PCRD CABLE FELL DOWN PCRD OT	REWINDING DONE ... RELEASED	07:00:00 11:40:00	07:20:00 11:50:00	
6	CHP	CC-37 SCR-7	SLEW LEFT NOT WORKING 30 DEGREE LIMIT WIRE PROBLEM	CONNECTED PROPERLY AND TESTED	08:30:00	08:45:00	
7	CHP	CC-34 SCR-1	SLEW LIMIT PROBLEM FROM C SHIFT	CABLE JOINT AND BYPASS REMOVED	10:00:00	10:15:00	
8	CHP	CC-28	TRIPPED ON OLR	RESET DONE	12:30:00	12:40:00	
9	CHP	CC-51	MPD TRIPPED 12 TIMES	RESET DONE	07:30:00	13:30:00	
10	CHP	CC-54	OLR ACTED 7 TIMES	RESET DONE	07:10:00	12:05:00	